

Modbus TCP/IP Ethernet Driver Help

© 2011 Kepware Technologies

Table of Contents

Table of Contents	2
Modbus TCP/IP Ethernet Driver Help	4
Overview	4
Channel Setup	5
Device Setup	7
Ethernet	8
Settings	9
Block Sizes	11
Variable Import Settings	12
Error Handling	12
Unsolicited	12
Cable Diagrams	13
Modbus Master & Modbus Unsolicited Considerations	14
Automatic Tag Database Generation	15
Exporting Variables from Concept	15
Exporting Variables from ProWORX	17
Optimizing Modbus TCP/IP Ethernet Communications	19
Data Types Description	20
Address Descriptions	21
Modbus Addressing	21
Output Coils	21
Input Coils	22
Internal Registers	22
Holding Registers	23
Driver System Tag Addressing	25
Mailbox Addressing	25
Instromet Addressing	26
Roxar Addressing	26
Fluenta Addressing	26
Applicom Addressing	26
Generic Modbus	26
TSX Premium	28
TSX Quantum	30
Error Descriptions	32
Address Validation	32
Address '<address>' is out of range for the specified device or register	33
Array size is out of range for address '<address>'	33
Array support is not available for the specified address: '<address>'	33
Data Type '<type>' is not valid for device address '<address>'	33
Device address '<address>' contains a syntax error	33
Device address '<address>' is not supported by model '<model name>'	33
Device address '<address>' is Read Only	34

Missing address	34
Device Status Messages	34
Device '<device name>' is not responding.....	34
Failed to resolve host '<host name>' on device '<device name>'.....	34
Unable to bind to adapter: '<network adapter name>'. Connect failed.....	35
Unable to create a socket connection for device '<device name>'.....	35
Unable to write to '<address>' on device '<device name>'.....	35
Unable to write to address '<address>' on device '<device>': Device responded with exception code '<code>'.....	35
Device Specific Messages	35
Bad address in block [x to y] on device '<device name>'.....	36
Bad array spanning ['<address>' to '<address>'] on device '<device name>'.....	36
Bad received length [x to y] on device '<device name>'.....	36
Cannot change device ID '<device ID>' from '<current mode>' to '<new mode>' with a client connected. ...	36
Failure to initiate 'winsock.dll'.....	37
Failure to start unsolicited communications.....	37
Unsolicited mailbox access for undefined device (IP: '<device IP>'. '<device index>')...Closing socket....	37
Unsolicited mailbox memory allocation error (IP: '<device IP>').....	37
Unsolicited mailbox unsupported request received (IP: '<device IP>').....	37
Automatic Tag Database Generation Messages	38
Description truncated for import file record number '<record>'.....	38
Error parsing import file record number '<record>', field '<field>'.....	38
File exception encountered during tag import.....	38
Imported tag name '<tag name>' is invalid. Name changed to '<tag name>'.....	38
Tag '<tag name>' could not be imported because data type '<data type>' is not supported.....	39
Tag import failed due to low memory resources.....	39
Modbus Exception Codes	39
Index	41

Modbus TCP/IP Ethernet Driver Help

Help version 1.062

CONTENTS

[Overview](#)

What is the Modbus TCP/IP Ethernet Driver?

[Channel Setup](#)

How do I configure a channel for use with this driver?

[Device Setup](#)

How do I configure a device for use with this driver?

[Automatic Tag Database Generation](#)

How can I easily configure tags for the Modbus TCP/IP Ethernet driver?

[Optimizing Your Modbus TCP/IP Ethernet Communications](#)

How do I get the best performance from the Modbus TCP/IP Ethernet driver?

[Data Types Description](#)

What data types does the Modbus TCP/IP Ethernet driver support?

[Address Descriptions](#)

How do I reference a data location in a Modbus TCP/IP Ethernet device?

[Error Descriptions](#)

What error messages does the Modbus TCP/IP Ethernet driver produce?

Overview


The Modbus TCP/IP Ethernet Driver provides an easy and reliable way to connect Modbus TCP/IP Ethernet devices to OPC Client applications, including HMI, SCADA, Historian, MES, ERP and countless custom applications. Users must install TCP/IP properly in order to use this driver. For more information on setup, refer to the Windows documentation.

Note: The driver will post messages when a failure occurs during operation.

Channel Setup

Ethernet

This dialog is used to specify channel-level ethernet settings. Channel-level settings apply to all devices that have been configured on the channel.



Socket Usage

This parameter specifies either **Share a single socket across all devices on this channel** or **Use one or more sockets per device on this channel**. Users must then enter a number in the **Max sockets per device** field.

The Modbus TCP/IP Ethernet driver will often use a Windows socket for each device on the network and maintains that socket as an active connection. Because the driver does not need to re-establish a connection each time it needs to read or write data to a given device, this provides a high level of performance. For a normal Modbus TCP/IP Ethernet enabled device, the default setting designed to give the best performance is **Use one or more sockets per device on this channel** and **Max sockets per device** as 1.

The default settings are not efficient for all applications, however. In some cases, it may be undesirable for the Modbus TCP/IP Ethernet driver to maintain a connection if the device has a limited number of connections available. The target device usually has a few or even a single port available for connections. If a product like the Modbus TCP/IP Ethernet driver is using that port, then no other system may access the target device. By checking **Share a single socket across all devices on this channel**, the Modbus TCP/IP Ethernet driver will be forced to use only a single Windows socket for all active devices on the current channel. In this mode, the driver will use the same Windows socket for all communications. Each time the driver switches to a new target device, the socket close and then reconnect with the next target. In this way, each device will only see a single connection.

The ability to put the Modbus TCP/IP Ethernet driver into single socket mode is very important for users who are trying to use the Modbus TCP/IP Ethernet driver to talk with a Modbus-Ethernet-to-Modbus-RTU bridge product. Most of these products allow the user to connect multiple RS-485 serial based devices to a single Modbus-Ethernet-to-Modbus-RTU bridge. When a gateway is handling a number of serial devices, the **Share a single socket across all devices on this channel** option must be unchecked.

Unsolicited Settings

The Modbus TCP/IP Ethernet driver in Master mode has the ability to accept unsolicited requests. When the driver is loaded by the OPC server, the driver starts a listening thread for unsolicited data. This thread is global to all channels configured in the OPC server; for example, if an OPC server project has three channels defined and the **Port Number** or **IP Protocol** setting is changed in one channel, the change made will be made to the other

two channels. The listening thread will be restarted once the change is applied. The Event Log will post an event for the restart. Descriptions of the parameters are as follows:

- **Port Number:** This parameter specifies the port number that the driver will use when listening for unsolicited requests. Valid port numbers are 0 to 65535. The default is 502.
- **IP Protocol:** This parameter specifies the protocol that the driver will use when listening for unsolicited request. There are two options: **User Datagram Protocol (UDP)** or **Transfer Control Protocol (TCP/IP)**.

Note: The Modbus TCP/IP Ethernet driver requires Winsock V1.1 or higher.

Device Setup

Supported Device Models

[Modbus Master](#)

[Modbus Unsolicited](#)

[Mailbox](#)

[Instromet](#)

[Roxar](#)

[Fluenta](#)

[Applicom](#)

[Ethernet to Modbus Plus Bridge](#)

See Also: [Cable Diagrams](#) and [Modbus Master & Modbus Unsolicited Considerations](#).

Maximum Number of Channels and Devices

The maximum number of supported channels is 256. The maximum number of supported devices is 8192.

Device ID (PLC Network Address)

The Device ID is used to specify the device IP address along with a Modbus Bridge Index on the Ethernet network.

Device IDs are specified as <HOST>.XXX, where HOST is a standard UNC/DNS name or an IP address. The XXX designates the Modbus Bridge Index of the device and can be in the range of 0 to 255. If no bridge is used, set the index to 0. Depending on the model selected and the Device ID, a device could be setup to act as an unsolicited device or a master. For more information on unsolicited mode, refer to [Modbus Unsolicited](#).

Examples

1. Request data from a Modicon TSX Quantum device with IP address 205.167.7.19. The Device ID should be entered as 205.167.7.19.0.
2. Request data from a Modbus Plus device connected to bridge index 5 of a Modbus TCP/IP Ethernet Bridge with an IP address of 205.167.7.50. The Device ID should be entered as 205.167.7.50.5.

Modbus Master

Almost all projects will use this model type when defining a device. This notifies the driver that a physical device is being connected to (such as Modicon TSX Quantum and other Modbus Open Ethernet compatible devices). When all devices are defined to be Modbus, the driver will act as a device on the network with a Device ID equivalent to the machine's IP address. The driver will accept any unsolicited commands it receives and attempt to process them as if it were just another PLC. Other devices can communicate with this simulated device using its IP address.

Addresses 1 to 65536 are implemented for output coils, input coils, internal registers and holding registers. The driver will respond to any valid request to read or write these values from external devices (Function Codes [decimal] 01, 02, 03, 04, 05, 06, 15, 16). Furthermore, Loopback (also known as Function code 08, sub code 00) has been implemented in this driver. These locations can be accessed locally by the Host PC as tags assigned to the slave device.

Note: Write Only access is not allowed for an unsolicited device.

Modbus Unsolicited

In unsolicited mode, the device acts like a device on the network. Every device simulates an actual Modbus device and responds to requests from any remote Modbus master. Similar to the master mode, the Device ID for the slave device is specified as YYY.YYY.YYY.YYY.XXX. For the device to act as a slave, the IP address part (YYY part) can be the loopback address or the local IP address of the PC running the Modbus TCP/IP Ethernet driver and the model has to be Modbus. The XXX designates the Station ID of the slave and can be in the range 0-255.

Multiple slave devices can have the same Station ID. In this scenario, all the devices that share the Station ID will point to one common simulated device. If the remote master requests data from a slave device (Station ID) that does not exist then the response will contain data from station '0'. Once a slave device is created in the project, that slave is enabled and will stay enabled until the server is shut down. Changing the Station ID will enable a new slave device, which will stay enabled until the server is shut down.

Mailbox

This model affects the way unsolicited requests are handled. By defining a mailbox device, the driver does not act like a PLC on the network. Instead, it acts as a storage area for each and every mailbox device defined. When the driver receives an unsolicited command, the driver detects the IP address the message came from and places the data in the storage area allocated for the device. If the message comes from a device with an IP address that has not been defined as a mailbox device, the message is not processed. Any client application that reads or writes to

this type of device, will read or write to the storage area are contained in the driver and not the physical device. For information on sending unsolicited requests to the Modbus TCP/IP Ethernet driver, consult the Modicon Documentation on the MSTR instruction.

Note: Modbus Mailbox does not support function code 22 (0x16). Only 0x10 (Holding Reg Write Multiple) and 0x6 (Holding Reg Write Single) are supported. It is possible to write to a single bit by turning off **Use holding register bit mask writes** in Device Properties under the settings tab. This forces it to use the Read/Modify/Write sequence instead of directly writing to the bit. Only the Master Modbus device (not the Mailbox) has to change its setting to get this to work.

See Also: [Settings for Mailbox Client Privileges](#)

Instromet

This model supports the non-standard Modbus mapping of Instromet devices.

Roxar

This model supports the non-standard Modbus mapping of the Roxar RFM Water Cut meter.

Fluenta

This model supports the non-standard Modbus mapping of the Fluenta FGM 100/130 Flow Computer.

Applicom


This model supports Applicom addressing syntax for Generic Modbus, TSX Premium, and TSX Quantum devices.

Ethernet to Modbus Plus Bridge

The driver also has the ability to talk to Modbus Plus devices via an Ethernet to Modbus Plus Bridge. The Device ID used should be the IP address of the bridge along with the Modbus Plus Bridge Index. For example, Bridge IP 205.167.7.12, Bridge Index 5 equates to a Device ID of 205.167.7.12.5. Consult the Modicon/Schneider Automation distributor on obtaining and setting up a MBE to MBP Bridge.

Ethernet

This dialog is used to specify device-level Master/Slave solicited communications settings.



Descriptions of the parameters are as follows:

- **Port Number:** This parameter specifies the port number that the remote device is configured to use. Valid port numbers are 0 to 65535. The default setting is 502. The Modbus TCP/IP Ethernet Driver will use

this port number when making solicited requests to a device.

Note: If the port system tag is used, the port number setting will be changed. For more information, refer to [Driver System Tag Addresses](#).

- **IP Protocol:** This parameter specifies whether the driver should connect to the remote device using the **User Datagram Protocol (UDP)** or **Transfer Control Protocol (TCP)**. The master and slave settings must match. For example, if the slave's IP protocol setting is TCP/IP, then the master's IP protocol setting for that device must also be TCP/IP.

Note: This driver requires Winsock V1.1 or higher.

- **Close TCP Socket on Timeout:** This option specifies whether the driver should close a TCP socket connection if the device does not respond within the timeout. When checked, the driver will close the TCP socket connection on timeout. When unchecked, the driver will continue to use the same TCP socket until an error is received, the physical device closes the socket, or the driver is shutdown. The default setting is checked.

Note: The Modbus TCP/IP Ethernet Driver will always close the socket connection on a socket error.

Settings

----- Data Access Group -----

Zero vs. One Based Addressing

If the address numbering convention for the device starts at one as opposed to zero, its value can be specified when defining the device's parameters. By default, user entered addresses will have one subtracted when frames are constructed to communicate with a Modbus device. If the device does not follow this convention, uncheck **Use zero based addressing** in Device Properties. For the appropriate application to obtain information on setting Device Properties, refer to the online help documentation. The default behavior follows the convention of the Modicon PLCs.

Zero vs One Based Bit Addressing Within Registers

Memory types that allow bits within Words can be referenced as a Boolean. The addressing notation for doing this is *<address>.<bit>*, where *<bit>* represents the bit number within the Word. Zero Based Bit addressing within registers provides two ways of addressing a bit within a given Word; Zero Based and One Based. Zero Based Bit addressing within registers simply means the "first bit" begins at 0. One Based bit addressing within registers means that the "first bit" begins at 1.

Zero Based Bit Addressing Within Registers (Default Setting/Checked)

Data Type	Bit Range
Word	Bits 0-15

One Based Bit Addressing Within Registers (Unchecked)

Data Type	Bit Range
Word	Bits 1-16

Holding Register Bit Mask Writes

When writing to a bit location within a holding register, the driver should only modify the bit of interest. Some devices support a special command to manipulate a single bit within a register (Function code hex 0x16 or decimal 22). If the device does not support this feature, the driver will need to perform a Read/Modify/Write operation to ensure that only the single bit is changed.

Check this box if the device supports holding register bit access. The default setting is unchecked. When checked, the driver will use function code 0x16, irrespective of the setting for **Use Modbus function 06 for single register writes**. When unchecked, the driver will use either function code 0x06 or 0x10 depending on the selection for **Use Modbus function 06 for single register writes**.

Note: When Modbus byte order is deselected, the byte order of the masks sent in the command will be Intel byte order.

Use Modbus Function 06 or 16

The Modbus driver has the option of using two Modbus protocol functions to write Holding register data to the target device. In most cases, the driver switches between these two functions based on the number of registers being written. When writing a single 16 bit register, the driver will generally use the Modbus function 06. When writing a 32 bit value into two registers, the driver will use Modbus function 16. For the standard Modicon PLC the use of either of these functions is not a problem. There are, however, a large number of third party devices that have implemented the Modbus protocol. Many of these devices support only the use of Modbus function 16 to write to Holding registers regardless of the number of registers to be written.

The **Use Modbus function 06** selection forces the driver to use only Modbus function 16 if needed. This selection is checked by default, allowing the driver to switch between 06 and 16 as needed. If a device requires all writes to be done using only Modbus function 16, uncheck this selection.

Note: For bit within word writes, the **Holding Register Bit Mask Writes** property takes precedence over this property **Use Modbus Function 06**. If **Holding Register Bit Mask Writes** is selected, then function code 0x16 is used no matter what the selection for this property. If **Holding Register Bit Mask Writes** is not selected, either function code 0x06 or 0x10 will be used for bit within word writes.

Use Modbus Function 05 or 15

The Modbus driver has the option of using two Modbus protocol functions to write output coil data to the target device. In most cases, the driver switches between these two functions based on the number of coils being written. When writing a single coil, the driver will use the Modbus function 05. When writing an array of coils, the driver will use Modbus function 15. For the standard Modicon PLC the use of either of these functions is not a problem. There are many third party devices that have implemented the Modbus protocol, however: many of these devices only support the use of Modbus function 15 to write to output coils regardless of the number of coils to be written.

The **Use Modbus function 05** selection forces the driver to use only Modbus function 15 if needed. This selection is checked by default, allowing the driver to switch between 05 and 15 as needed. If a device requires all writes to be done using only Modbus function 15, uncheck this selection.

Mailbox Client Privileges for Mailbox Device Model

Read Only: Client applications can only read from a mailbox memory map.

Memory Map Writes: Client applications can read and write to the mailbox memory map.

Device Writes: Client applications can only write to a device; reads are from the memory map.

----- Data Encoding Group -----

Modbus Byte Order

The byte order used by the Ethernet driver can be changed from the default Modbus byte ordering to Intel byte ordering by using this selection. This selection will be checked by default, which is the normal setting for Modbus compatible devices. If the device uses Intel byte ordering, deselecting this selection will enable the Modbus driver to properly read Intel formatted data.

First Word Low in 32 Bit Data Types

Two consecutive registers' addresses in a Modbus device are used for 32 bit data types. It can be specified whether the driver should assume the first word is the low or the high word of the 32 bit value. The default, first word low, follows the convention of the Modicon Modsoft programming software.

First DWord Low in 64 Bit Data Types

Four consecutive registers' addresses in a Modbus device are used for 64 bit data types. It can be specified whether the driver should assume the first DWord is the low or the high DWord of the 64 bit value. The default, first DWord low, follows the default convention of 32 bit data types.

Use Modicon Bit Ordering

When checked, the driver will reverse the bit order on reads and writes to registers to follow the convention of the Modicon Modsoft programming software. For example, a write to address 40001.0/1 will affect bit 15/16 in the device when this option is enabled. This option is disabled (unchecked) by default.

Note: For the following example, the 1st through 16th bit signifies either 0-15 bits or 1-16 bits depending on if the driver is set at Zero Based or One Based Bit Addressing within registers.

MSB=Most Significant Bit

LSB=Least Significant Bit

Use Modicon Bit Ordering Checked

MSB								LSB							
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16

Use Modicon Bit Ordering Unchecked (Default Setting)

MSB								LSB							
16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1

Data Encoding Options Details

The following summarizes usage of the Data Encoding options.

- Use default Modbus byte order option sets the data encoding of each register/16 bit value.
- First word low in 32 bit data types option sets the data encoding of each 32 bit value and each double word of a 64 bit value.
- First DWord low in 64 bit data types option sets the data encoding of each 64 bit value.

Data Types	Use default Modbus byte order Applicable	First word low in 32 bit data types Applicable	First DWord low in 64 bit data types Applicable
Word, Short, BCD	Yes	No	No
Float, DWord, Long, LBCD	Yes	Yes	No
Double	Yes	Yes	Yes

If needed, use the following information and the device's documentation to determine the correct settings of the Data Encoding options. The default settings are acceptable for the majority of Modbus devices.

Data Encoding Group Option	Data Encoding	
Use default Modbus byte order Checked	High Byte (15..8)	Low Byte (7..0)
Use default Modbus byte order Unchecked	Low Byte (7..0)	High Byte (15..8)
First word low in 32 bit data types Unchecked	High Word (31..16)	Low Word (15..0)
	High Word(63..48) of Double Word in 64 bit data types	Low Word (47..32) of Double Word in 64 bit data types
First word low in 32 bit data types Checked	Low Word (15..0)	High Word (31..16)
	Low Word (47..32) of Double Word in 64 bit data types	High Word (63..48) of Double Word in 64 bit data types
First DWord low in 64 bit data types Unchecked	High Double Word (63..32)	Low Double Word (31..0)
First DWord low in 64 bit data types Checked	Low Double Word (31..0)	High Double Word (63..32)

Block Sizes

Coil Block Sizes

Coils can be read from 8 to 2000 points (bits) at a time.

Register Block Sizes

From 1 to 120 standard Modbus registers (16 bit) can be read at a time. Models such as the Instromet, Roxar and Fluenta (which support 32 bit and 64 bit registers) require special consideration. The Modbus protocol constrains the block size to be no larger than 256 bytes. This translates to a maximum of block size of 64 32 bit registers, or 32 64 bit registers for these models.

Caution: A "Bad address in block error" could occur if the Register Block sizes value is set above 120 and a 32 or 64 bit data type is used for any tag. To prevent this from occurring, decrease the block size value to 120.

Reasons to Change the Default Block Sizes

1. The device may not support block Read/Write operations of the default size. Smaller Modicon PLCs and non-Modicon devices may not support the maximum data transfer lengths supported by the Modbus TCP/IP Ethernet network.
2. The device may contain non-contiguous addresses. If this is the case and the driver attempts to read a block of data that encompasses undefined memory, the device will probably reject the request.

Perform Block Read on Strings

Check this option to block read string tags, which are normally read individually. When this option is selected, string tags will be grouped together depending on the selected block size. Block reads can only be performed for Modbus model string tags.

Variable Import Settings

Variable Import File

This parameter specifies the exact location of the Concept or ProWORX variable import file that the driver should use when the Automatic Tag Database Generation feature is enabled.


Display Descriptions

When checked, this option will use imported tag descriptions (if present in file).

Note: For more information on configuring the Automatic Tag Database Generation feature (and how to create a variable import file), refer to [Automatic Tag Database Generation](#).

Error Handling

When checked, the **Deactivate tags on illegal address exception** parameter instructs the driver to stop polling for a block of data if the device returns Modbus exception code 2 (illegal address) or 3 (illegal data, such as number of points) in response to a Read of that block. When unchecked, addresses that have become accessible can be read in a dynamic fashion in the device. The default setting is checked.



Unsolicited

OPC Quality Bad Until Write

This option controls the initial OPC quality of tags attached to this driver. When unchecked, all tags will have an initial value of 0 and an OPC quality of Good. This is the default condition. When checked, all tags will have an initial value of 0 and an OPC quality of Bad. The tag's quality will remain Bad until all coils or registers referenced by the tag have been written to by a Modbus master or a client application. For example, a tag with address 400001

and data type DWord references two holding registers: 400001 and 400002. This tag will not show Good quality until both holding registers have been written to.

Note: If the device is not in unsolicited mode, this option will be grayed out.

Communications Timeout: ____ Seconds

The communications timeout parameter sets the amount of time the driver will wait for an incoming request before setting the device's tag quality to bad. After the timeout has occurred, the only way to reset the timeout and allow all the tags to be processed normally is to re-establish communications with the remote master or disable the communications timeout by setting it to 0.

If an incoming request comes for a slave device (Station ID) that does not exist, the request is always directed to station '0'. In this case, the timeout for a slave device with Station ID '0' will not occur even if it does not explicitly receive any remote communications for the timeout period.

Disabled: 0
 Enabled: 1-->64,800 seconds (18 hours)


Note 1: Unsolicited devices require Model=Modbus and Device ID=IP_Address.yyy, where IP_Address can be the local IP address of the PC running the driver (or 127.xxx.xxx.xxx, where xxx=0-255, and yyy (Station ID)=0-255).

Note 2: When the first unsolicited request for a slave device is received, the Event Log will display the following informational message: "<date>__<time>__<level>__<source>__<event>". For example, "2/4/2011__4:53:10 PM Information__Modbus TCP/IP Ethernet__Created Memory for Slave Device <Slave Number>".


Note 3: For this driver, the terms Slave and Unsolicited are used interchangeably.

Cable Diagrams


Patch Cable (Straight Through)



10 BaseT



Crossover Cable



8-pin RJ45

Modbus Master & Modbus Unsolicited Considerations

The following notes pertain to both Modbus Master and Modbus Unsolicited devices.

- It is not recommended that a Mailbox device and a Modbus device be on the same machine. Since a master will only get data from one of these devices at a time, it is uncertain from which it will get data.
- It is recommended that master and unsolicited devices be placed on separate channels in the server project for optimal unsolicited device tag processing.
- When a client is connected, the Device ID can only be changed if it does not result in change of mode (master to slave or slave to master) of the device. The mode is changed by changing the loopback* or local IP address to a different IP address and vice versa. The loopback address and the local IP address (of the PC running the driver) indicates slave (unsolicited) mode and any other IP address indicates master mode of the device. When no client is connected, the mode can be changed in any manner (such as, master to master, master to slave, slave to slave or slave to master).

*Any address in the format 127.xxx.xxx.xxx, where xxx is in the range 0-255 is loopback address.

- The Data Encoding Group settings must be the same in master and slave devices. For example, when a device configured as a Modbus master is communicating with the device setup as a Modbus slave.
- For this driver, the terms Slave and Unsolicited are used interchangeably.

Automatic Tag Database Generation

Overview

This driver makes use of the OPC server's automatic tag database generation feature. This enables drivers to automatically create tags that access data points used by the device's ladder program. Although it is sometimes possible to query a device for the information needed to build a tag database, this driver must use a **Variable Import File** instead. Variable import files can be generated using the Concept and ProWORX device programming applications.

Creating the Variable Import File

The import file must be in semicolon delimited Concept ".txt" format. This is the default export file format of the Concept device programming application. The ProWORX programming application can also export variable data in this format. For application-specific information on creating the variable import file, refer to [Exporting Variables from Concept](#) and [Exporting Variables from ProWORX](#).

OPC Server Configuration

The automatic tag database generation feature can be customized to fit particular needs. The primary control options can be set during the Database Creation step of the Device Wizard or later by selecting **Device Properties | Database Creation**. For more information, refer to the OPC server's help documentation.


In addition to these basic settings, which are common to all drivers that support automatic tag database generation, this driver requires additional settings. These specialized settings include the name and location of the variable import file. This information can be specified during the Variable Import Settings step of the Device Wizard or later by selecting **Device Properties | Variable Import Settings**. For more information, refer to [Variable Import Settings](#).

Operation

Depending on the configuration, tag generation may start automatically when the OPC server project starts or be initiated manually at some other time. The OPC server's event log will show when the tag generation process started, any errors that occurred while processing the variable import file and when the process completed.

Exporting Variables from Concept

As the ladder program is created, symbolic names for the various data points referenced using the **Variable Editor** can be defined. Additional symbols and constants that are not used by the ladder program can also be defined.



Note: Although Concept allows variable names to be defined that begin with an underscore, such names are not allowed by the OPC server. The driver will modify invalid imported tag names as needed and will make note of any such name changes in the server's event log.

User defined data types are not currently supported by this driver. Records in the export file containing references to such types will be ignored. The following simple data types are supported:

Concept Data Type	Generated Tag Data Type
Bool	Boolean
Byte	Word
Dint	Long
Int	Short
Real	Float
Time	DWord
Udint	DWord
Uint	Word
Word	Word


Note 1: Unlocated variables, which are those that do not correspond to a physical address in the device, will be ignored by the driver.

Note 2: Comments are allowed and included as the generated tag descriptions. For more information, refer to [Variable Import Settings](#).

Exporting Data from Concept


Once the variables have been defined, the data must be exported from Concept.

1. Click **File | Export** and then select the **Variables: Text delimited** format.
2. Click **OK**.



3. Specify the filter and separator settings.

Note: Choose the filter settings as desired, but remember that this driver will only be able to read the exported data if the default semicolon separator is used.



4. Click **OK** to generate the file.

Exporting Variables from ProWORX

In order for ProWORX to export the necessary variable information, the **Symbols** option must be checked under **File | Preferences**. Symbolic names for various data points referenced can be defined while creating the ladder program by using the **Document Editor**.

The screenshot shows the 'Documentation Editor (10100)' dialog box. It has a blue title bar with a close button. The main area is divided into several sections: 'Descriptor:' with a text box containing 'Line 1 alarm'; 'Symbol:' with a text box containing 'Alarm_1' and a checkbox labeled 'MMI'; 'Short Comment:' with a large empty text area; 'Page Title:' with an empty text box; 'Long Comment:' with an empty text box, a 'Next Available' button, and radio buttons for 'Leading' and 'Trailing', along with an 'Expand' button; 'Navigate By:' with radio buttons for 'Reference' (selected) and 'Symbol', and a text box containing '10100' with arrow buttons; 'Copy Record', 'Cut Record', 'Paste Record', and 'Delete Record' buttons; and a row of buttons at the bottom: 'OK', 'Cancel', 'Summary...', 'Search...', 'Goto...', 'Add Bits', and 'Help'.


Note 1: Although ProWORX does not place many restrictions on variable names, the OPC server requires that tag names consist of only alphanumeric characters and underscores. It also requires that the first character cannot be an underscore. The driver will modify invalid imported tag names as needed, and any such name changes will be noted in the server's event log.

Note 2: ProWORX will assign a data type of either Bool or Int to the exported variables. The driver will create tags of type Boolean and Short respectively. To generate tags with other data types, the exported file must be manually edited and use any of the supported Concept data types. For a list of supported types, refer to [Exporting Variables from Concept](#).

Exporting Data From ProWorx

Once the variables have been defined, the data must be exported from ProWORX.

1. Select **File | Utilities | Import/Export**.
2. Select the **Export** and the **Concept .TXT** file formats.
3. Descriptors are allowed, and can be included as the generated tag descriptions. For more information, refer to [Variable Import Settings](#).




4. Click **OK** to generate the file.

Optimizing Modbus TCP/IP Ethernet Communications


The Modbus TCP/IP Ethernet driver has been designed to provide the best performance with the least amount of impact on the system's overall performance. While the Modbus TCP/IP Ethernet driver is fast, there are a couple of guidelines that can be used in order to control and optimize the application and gain maximum performance.

The server refers to communications protocols like Modbus TCP/IP Ethernet as a channel. Each channel defined in the application represents a separate path of execution in the server. Once a channel has been defined, a series of devices must then be defined under that channel. Each of these devices represents a single Modbus controller from which data will be collected. While this approach to defining the application will provide a high level of performance, it won't take full advantage of the Modbus TCP/IP Ethernet driver or the network. An example of how the application may appear when configured using a single channel is shown below.



Each device appears under a single Modbus TCP/IP Ethernet channel. In this configuration, the driver must move from one device to the next as quickly as possible in order to gather information at an effective rate. As more devices are added or more information is requested from a single device, the overall update rate begins to suffer.

If the Modbus TCP/IP Ethernet driver could only define one single channel, then the example shown above would be the only option available; however, the Modbus TCP/IP Ethernet driver can define up to 256 channels. Using multiple channels distributes the data collection workload by simultaneously issuing multiple requests to the network. An example of how the same application may appear when configured using multiple channels to improve performance is shown below.



Each device has now been defined under its own channel. In this new configuration, a single path of execution is dedicated to the task of gathering data from each device. If the application has 256 or fewer devices, it can be optimized exactly how it is shown here.

The performance will improve even if the application has more than 256 devices. While 256 or fewer devices may be ideal, the application will still benefit from additional channels. Although by spreading the device load across all 256 channels will cause the server to move from device to device again, it can now do so with far less devices to process on a single channel.

Block Size

Block size is another parameter that can affect the performance of the Modbus TCP/IP Ethernet driver. The block size parameter is available on each device being defined (on the OPC server screen, right-click on the device, choose Properties and click the Blocks tab). The block size refers to the number of registers or bits that may be requested from a device at one time. The driver's performance can be refined by configuring the block size to 1 to 120 registers and 8 to 2000 bits.

An additional performance gain can be realized by increasing the **Maximum outstanding requests per socket** value. For more information, refer to [Device Level Ethernet Settings](#).

Data Types Description

Data Type	Description
Boolean	Single bit
Word	Unsigned 16 bit value bit 0 is the low bit bit 15 is the high bit
Short	Signed 16 bit value bit 0 is the low bit bit 14 is the high bit bit 15 is the sign bit
DWord	Unsigned 32 bit value bit 0 is the low bit bit 31 is the high bit
Long	Signed 32 bit value bit 0 is the low bit bit 30 is the high bit bit 31 is the sign bit
BCD	Two byte packed BCD Value range is 0-9999. Behavior is undefined for values beyond this range.
LBCD	Four byte packed BCD Value range is 0-99999999. Behavior is undefined for values beyond this range.
String	Null terminated ASCII string Supported on Modbus Model, includes Hi-Lo Lo-Hi byte order selection.
Double*	64 bit floating point value The driver interprets four consecutive registers as a double precision value by making the last two registers the high DWord and the first two registers the low DWord.
Double Example	If register 40001 is specified as a double, bit 0 of register 40001 would be bit 0 of the 64 bit data type and bit 15 of register 40004 would be bit 63 of the 64 bit data type.
Float*	32 bit floating point value The driver interprets two consecutive registers as a single precision value by making the last register the high word and the first register the low word.
Float Example	If register 40001 is specified as a float, bit 0 of register 40001 would be bit 0 of the 32 bit data type and bit 15 of register 40002 would be bit 31 of the 32 bit data type.

*The descriptions assume the default; that is, first DWord low data handling of 64 bit data types and first word low data handling of 32 bit data types.

Address Descriptions

Address specifications vary depending on the model in use. Select a link from the following list to obtain specific address information for the model of interest.

[Modbus](#)
[Mailbox](#)
[Instromet](#)
[Roxar](#)
[Fluenta](#)
[Applicom](#)

Modbus Addressing

Modbus devices support the following addresses. Click on a link below for more information.

[Output Coils](#)
[Input Coils](#)
[Internal Registers](#)
[Holding Registers](#)

Output Coils

Decimal Addressing

Address	Range	Data Type	Access	Function Code
0xxxxx	1-65536	Boolean	Read/Write	01, 05, 15

Hexadecimal Addressing

Address	Range	Data Type	Access
H0yyyyy	1-10000	Boolean	Read/Write

Mailbox Mode

Only Holding Registers are supported in [Mailbox mode](#).

Example

The 255th output coil would be addressed as '0255' using decimal addressing or 'H0FF' using hexadecimal addressing.

Array Support

Arrays are also supported for the output coil addresses. The syntax for declaring an array (using decimal addressing) is as follows:

0xxxx[cols]
 with assumed row count of 1 or 0xxxx[rows][cols].

The base address+(rows*cols) cannot exceed 65536. The total number of coils being requested cannot exceed the output coil block size that was specified for this device.

Packed Coil Address Type

The Packed Coil address type allows access to multiple consecutive coils as an analog value. This feature is available for both input coils and output coils, polled mode only. The only valid data type is Word.

Note: This is not available for devices that are set up to access the unsolicited memory map or Mailbox Mode.

Decimal Addressing

Address	Range	Data Type	Access	Function Code
0xxxxx#nn	xxxxx=1-65521 nn=1-16	Word	Read/Write	01,15

Hexadecimal Addressing

Address	Range	Data Type	Access
H0yyyyy#nn	yyyyy=1-FFF1 nn=1-16	Word	Read/Write

Note 1: The bit order will be such that the start address will be the LSB (least significant bit) of analog value.

Note 2: For this driver, the terms Slave and Unsolicited are used interchangeably.

Input Coils

Decimal Addressing

Address	Range	Data Type	Access*	Function Code
1xxxxx	1-65536	Boolean	Read Only	02

*For slave devices, Read Only locations are Read/Write.

Hexadecimal Addressing

Address	Range	Data Type	Access*
H1yyyyy	1-10000	Boolean	Read Only

*For slave devices, Read Only locations are Read/Write.

Note: For this driver, the terms Slave and Unsolicited are used interchangeably.

Mailbox Mode

Only Holding Registers are supported in [Mailbox Mode](#).

Example

The 127th input coil would be addressed as '10127' using decimal addressing or 'H107F' using hexadecimal addressing.

Array Support

Arrays are also supported for the input coil addresses. The syntax for declaring an array (using decimal addressing) is as follows:

1xxxx[cols]
with assumed row count of 1 or 1xxxx[rows][cols].

The base address+(rows*cols) cannot exceed 65536. The total number of coils being requested cannot exceed the input coil block size that was specified for this device.

Packed Coil Address Type

The Packed Coil address type allows access to multiple consecutive coils as an analog value. This feature is available for both input coils and output coils, polled mode only. The only valid data type is Word.

Note: This is not available for devices that are set up to access the unsolicited memory map or Mailbox Mode.

Decimal Addressing

Address	Range	Data Type	Access	Function Code
0xxxxx#nn	xxxxx=1-65521 nn=1-16	Word	Read Only	02

Hexadecimal Addressing

Address	Range	Data Type	Access
H0yyyyy#nn	yyyyy=1-FFF1 nn=1-16	Word	Read Only

Note: The bit order will be such that the start address will be the LSB (least significant bit) of analog value.

Internal Registers

The default data types are shown in **bold**.

Decimal Addressing

Address	Range	Data Type	Access*	Function Code
3xxxxx	1-65536	Word , Short, BCD	Read Only	04

3xxxx.bb	xxxx=1-65536 bb=0/1-15/16**	Boolean	Read Only	04
3xxxx	1-65535	Float, DWord, Long, LBCD	Read Only	04
3xxxx	1-65533	Double	Read Only	04
Internal Registers As String with HiLo Byte Order	300001.2H-365536.240H .Bit is string length, range 2 to 240 bytes.	String	Read Only	04
Internal Registers As String with LoHi Byte Order	300001.2L-365536.240L .Bit is string length, range 2 to 240 bytes.	String	Read Only	04

*For slave devices, Read Only locations are Read/Write.

**For more information, refer to Use 0-Based Bit Addressing under [Settings](#).

Hexadecimal Addressing

Address	Range	Data Type	Access*
H3yyyyy	1-10000	Word , Short, BCD	Read Only
H3yyyyy.cc	yyyyy=1-10000 cc=0/1-F/10	Boolean	Read Only
H3yyyy	1-FFFF	Float, DWord, Long, LBCD	Read Only
H3yyyy	1-FFFD	Double	Read Only
Internal Registers As String with HiLo Byte Order	H300001.2H-H3FFFF.240H .Bit is string length, range 2 to 240 bytes.	String	Read Only
Internal Registers As String with LoHi Byte Order	H300001.2L-H3FFFF.240L .Bit is string length, range 2 to 240 bytes.	String	Read Only

*For slave devices, Read Only locations are Read/Write.

Note: For this driver, the terms Slave and Unsolicited are used interchangeably.

Mailbox Mode

Only Holding Registers are supported in Mailbox Mode. The double data type is not supported. For more information, refer to [Mailbox Mode](#).

Array Support

Arrays are supported for internal register locations for all data types except Boolean and String. The syntax for declaring an array (using decimal addressing) is as follows:

3xxx[cols] with assumed row count of 1.
3xxx[rows][cols].

For Word, Short and BCD arrays, the base address+(rows*cols) cannot exceed 65536.

For Float, DWord, Long and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65536.

For all arrays, the total number of registers being requested cannot exceed the internal register block size that was specified for this device.

Holding Registers

The default data types are shown in **bold**.

Decimal Addressing

Address	Range	Data Type	Access	Function
---------	-------	-----------	--------	----------

				Code
4xxxxx	1-65536	Word, Short, BCD	Read/Write	03, 06, 16
4xxxxx.bb	xxxx=1-65536 bb=0/1-15/16*	Boolean	Read/Write	03, 06, 16, 22
4xxxxx	1-65535	Float, DWord, Long, LBCD	Read/Write	03, 06, 16
4xxxxx	1-65533	Double	Read/Write	03, 06, 16
Holding Registers As String with HiLo Byte Order	400001.2H- 465536.240H .Bit is string length, range 2 to 240 bytes.	String	Read/Write	03, 16
Holding Registers As String with LoHi Byte Order	400001.2L-465536.240L .Bit is string length, range 2 to 240 bytes.	String	Read/Write	03, 16

*For more information, refer to Use 0-Based Bit Addressing under [Settings](#).

Hexadecimal Addressing

Address	Range	Data Type	Access
H4yyyyy	1-10000	Word, Short, BCD	Read/Write
H4yyyyy.c	yyyyy=1-10000 cc=0/1-F/10	Boolean	Read/Write
H4yyyy	1-FFFF	Float, DWord, Long, LBCD	Read/Write
H4yyyy	1-FFFD	Double	Read/Write
Holding Registers As String with HiLo Byte Order	H400001.2H-H4FFFF.240H .Bit is string length, range 2 to 240 bytes.	String	
Holding Registers As String with LoHi Byte Order	H400001.2L-H4FFFF.240L .Bit is string length, range 2 to 240 bytes.	String	Read/Write

Write Only Access

All Read/Write addresses may be set as Write Only by prefixing a W to the address such as "W40001", which will prevent the driver from reading the register at the specified address. Any attempts by the client to read a Write Only tag will result in obtaining the last successful write value to the specified address. If no successful writes have occurred, then the client will receive 0/NULL for numeric/string values for an initial value.

Caution: Setting the Write Only tags client access privileges to Read Only will cause writes to these tags to fail and the client to always receive 0/NULL for numeric/string values.

Mailbox Mode

Only Holding Registers are supported in Mailbox Mode. When read from a client, the data is read locally from a cache, not from a physical device. When written to from a client, the data is written to both the local cache and the physical device as determined by the Device ID routing path. For more information, refer to [Mailbox Mode](#).

Note: Double data type is not supported.

String Support

The Modbus model supports reading and writing holding register memory as an ASCII string. When using holding registers for string data, each register will contain two bytes of ASCII data. The order of the ASCII data within a given register can be selected when the string is defined. The length of the string can be from 2 to 240 bytes and is entered in place of a bit number. The length must be entered as an even number. Appending either an "H" or "L" to the address specifies the byte order.

Note: For more information on performing block read on string tags for the Modbus model, refer to [Block Sizes](#).

String Examples

1. To address a string starting at 40200 with a length of 100 bytes and Hi-Lo byte order, enter:
40200.100H

2. To address a string starting at 40500 with a length of 78 bytes and Lo-Hi byte order, enter:
40500.78L

Note: String length may be limited by the maximum size of the write request that the device allows. If the error message "Unable to write to address <address> on device<device> : Device responded with exception code 3" is received in the server event window, the device did not like the length of the string. If possible, try shortening the string.

Array Support

Arrays are supported for holding register locations for all data types except Boolean and String. The syntax for declaring an array (using decimal addressing) is as follows:

4xxx[cols] with assumed row count of 1.
4xxx[rows][cols].

For Word, Short and BCD arrays, the base address+(rows*cols) cannot exceed 65536.

For Float, DWord, Long and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65535.

For all arrays, the total number of registers being requested cannot exceed the holding register block size that was specified for this device.

Driver System Tag Addressing

Port Tag

The Port system tag allows a client application to read and write the Port Number setting. Writes to this tag will cause the driver to disconnect from the device and attempt to reconnect to the specified port. It will also modify the project: the server will prompt a save on modified projects on shutdown.

Note: The Device Port Number setting is not used by the driver for unsolicited communications.

Address: Port (not case sensitive)

Data Types: Word, Short, DWord, Long

Access: Read/Write

Note: For this driver, the terms Slave and Unsolicited are used interchangeably.

See Also: [Device Level Ethernet Settings](#)

Mailbox Addressing

The default data types are shown in **bold**.

Decimal Addressing

Address	Range	Data Type	Access
4xxxxx	1-65536	Word, Short, BCD	Read/Write
4xxxxx.bb	xxxxx=1-65536 bb=0-15	Boolean	Read/Write
4xxxxx	1-65535	Float, DWord, Long, LBCD	Read/Write

Hexadecimal Addressing

Address	Range	Data Type	Access
H4yyyyy	1-10000	Word, Short, BCD	Read/Write
H4yyyyy.c	yyyyy=1-10000 c=0-F	Boolean	Read/Write
H4yyyyy	1-FFFF	Float, DWord, Long, LBCD	Read/Write

Note: Modbus Mailbox does not support function code 22 (0x16). Only 0x10 (Holding Reg Write Multiple) and 0x6 (Holding Reg Write Single) are supported. It is possible to write to a single bit by turning off **Use holding register bit mask writes** in Device Properties under the settings tab. This forces it to use the Read/Modify/Write sequence instead of directly writing to the bit. Only the **Master Modbus** device (not the Mailbox) has to change its setting to get this to work.

Arrays

Arrays are also supported for the holding register addresses. The syntax for declaring an array (using decimal addressing) is as follows:

4xxxx[cols] with assumed row count of 1.
4xxxx[rows][cols].

For Word, Short and BCD arrays, the base address+(rows*cols) cannot exceed 65536.

For Float, DWord, Long and Long BCD arrays, the base address+(rows*cols* 2) cannot exceed 65535.

For all arrays, the total number of registers being requested cannot exceed the holding register block size that was specified for this device.

Instromet Addressing

The default data types are shown in **bold**.

Address	Range	Data Type	Access
Short Integers	400000-400199	Word , Short	Read Only
Long Integers	400200-400399	DWord , Long	Read Only
Floats	400400-400599	Float	Read Only

Roxar Addressing

The default data types are shown in **bold**.

Address	Range	Data Type	Access
Short Integers	403000-403999	Word , Short	Read/Write
Floats	407000-407999	Float	Read/Write
Floats	409000-409999	Float	Read Only

Fluenta Addressing

The default data types are shown in **bold**.

Address	Range	Data Type	Access
System	400000-409999	Float , Double	Read/Write
Output	410000-410999	Float , Double	Read Only
	420000-420999		
	430000-430999		
User	411000-411999	Float , Double	Read/Write
	421000-421999		
	431000-431999		
Service	412000-412999	Float , Double	Read/Write
	422000-422999		
	432000-432999		
Accumulation	413000-413999	Float , Double	Read Only
	423000-423999		
	433000-433999		

Applicom Addressing

Applicom devices support three Applicom sub-models. For address information, select a link from the list below.

[Generic Modbus](#)
[TSX Premium](#)
[TSX Quantum](#)

Generic Modbus

Output Coils

Address	Range	Data Type	Access	Function Code
Bxxxxx	0-65535	Boolean	Read/Write	01, 05, 15

Array Support

Arrays are supported for the output coil addresses. The syntax for declaring an array is as follows:

Bxxxxx_cols with assumed row count of 1.
Bxxxxx_rows_cols.

The base address+(rows*cols) cannot exceed 65535. The total number of coils being requested cannot exceed the output coil block size that was specified for this device.

Input Coils

Address	Range	Data Type	Access	Function Code
BIxxxxx	0-65535	Boolean	Read Only	02

Array Support

Arrays are supported for the input coil addresses. The syntax for declaring an array is as follows:

BIxxxxx_cols with assumed row count of 1.
BIxxxxx_rows_cols.

The base address+(rows*cols) cannot exceed 65535. The total number of coils being requested cannot exceed the input coil block size that was specified for the device.

Internal Registers

The default data types are shown in **bold**.

Address	Range	Data Type	Access*	Function Code
WIxxxxx	0-65535 0-65534 0-65532	Word , Short, BCD Float, DWord, Long, LBCD Double	Read Only	04
WIxxxxx.bb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read Only	04
WIxxxxx:Xbb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read Only	04
DIxxxxx	0-65534	DWord	Read Only	04
FIxxxxx	0-65534	Float	Read Only	04
WIxxxxx_S	0-65535	Short	Read Only	04
WIxxxxx_B	0-65535	BCD	Read Only	04
WIxxxxx_A***	0-65535	String	Read Only	04
DIxxxxx_S	0-65534	Long	Read Only	04
DIxxxxx_B	0-65534	LBCD	Read Only	04
M_WIxxxxx_n(H) String with HiLo Byte Order (H optional)	xxxxx=0-65535 n is string length range is 1 to 120 words	String	Read Only	04
M_WIxxxxx_nL String with LoHi Byte Order	xxxxx=0-65535 n is string length range is 1 to 120 words	String	Read Only	04

*For slave devices, Read Only locations are Read/Write.

**For more information, refer to "Use 0-Based Bit Addressing" under [Settings](#).

***The length of the string is 2 bytes.

Array Support

Arrays are supported for the internal register addresses. The syntax for declaring an array is as follows:

WIxxxxx_cols with assumed row count of 1.
WIxxxxx_rows_cols.

For Word, Short, and BCD arrays, the base address+(rows*cols) cannot exceed 65535.

For Float, DWord, Long, and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65534.

For all arrays, the total number of registers being requested cannot exceed the internal register block size that was specified for the device.

Holding Registers

The default data types are shown in **bold**.

Address	Range	Data Type	Access*	Function Code
Wxxxxx	0-65535 0-65534 0-65532	Word , Short, BCD Float, DWord, Long, LBCD Double	Read/Write	03, 06, 16
Wxxxxx.bb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
Wxxxxx:Xbb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
Dxxxxx	0-65534	DWord	Read/Write	03, 06, 16
Dxxxxx.bb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
Fxxxxx	0-65534	Float	Read/Write	03, 06, 16
Fxxxxx.bb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
Wxxxxx_S	0-65535	Short	Read/Write	03, 06, 16
Wxxxxx_B	0-65535	BCD	Read/Write	03, 06, 16
Wxxxxx_A***	0-65535	String	Read Only	03, 16
Dxxxxx_S	0-65534	Long	Read/Write	03, 06, 16
Dxxxxx_B	0-65534	LBCD	Read/Write	03, 06, 16
M_Wxxxxx_n(H) String with HiLo Byte Order (H optional)	xxxxx=0-65535 n is string length range is 1 to 120 words	String	Read/Write	03, 16
M_Wxxxxx_nL String with LoHi Byte Order	xxxxx=0-65535 n is string length range is 1 to 120 words	String	Read/Write	03, 16

*For slave devices, Read Only locations are Read/Write.

**For more information, refer to "Use 0-Based Bit Addressing" under [Settings](#).

***The length of the string is 2 bytes.

Array Support

Arrays are supported for the holding register addresses. The syntax for declaring an array using decimal addressing is as follows.

Wxxxxx_cols with assumed row count of 1.

Wxxxxx_rows_cols.

For Word, Short, and BCD arrays, the base address+(rows*cols) cannot exceed 65535.

For Float, DWord, Long, and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65534.

For all arrays, the total number of registers being requested cannot exceed the holding register block size that was specified for the device.

String Support

The Applicom model supports reading and writing holding register memory as an ASCII string. When using holding registers for string data, each register will contain two bytes of ASCII data. The length of the string can be from 1 to 120 words. For more information on performing a block read on string tags, refer to [Block Sizes](#).

Note: String length may be limited by the maximum size of the write request allowed by the device. If the error message "Unable to write to address <address> on device<device> : Device responded with exception code 3" is received in the server event window, the device did not like the length of the string. If possible, try shortening the string.

TSX Premium

Output Coils

Address	Range	Data Type	Access	Function Code
%Mxxxxxx	0-65535	Boolean	Read/Write	01, 05, 15
%Mxxxxxx	0-65535	Boolean	Read/Write	01, 05, 15

Array Support

Arrays are supported for the output coil addresses. The syntax for declaring an array is as follows:

%MXXXXX_cols with assumed row count of 1.
%MXXXXX_rows_cols.

The base address+(rows*cols) cannot exceed 65535. The total number of coils being requested cannot exceed the output coil block size that was specified for the device.

Holding Registers

The default data types are shown in **bold**.

Address	Range	Data Type	Access*	Function Code
%MWxxxxx	0-65535 0-65534 0-65532	Word , Short, BCD Float, DWord, Long, LBCD Double	Read/Write	03, 06, 16
%MWxxxxx.bb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
%MWxxxxx:Xbb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
%DWxxxxx (or %MDxxxxx)	0-65534	DWord	Read/Write	03, 06, 16
%DWxxxxx.bb (or %MDxxxxx.bb)	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
%FWxxxxx (or %MFxxxxx)	0-65534	Float	Read/Write	03, 06, 16
%FWxxxxx.bb (or %MFxxxxx.bb)	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
%MWxxxxx_S	0-65535	Short	Read/Write	03, 06, 16
%MWxxxxx_B	0-65535	BCD	Read/Write	03, 06, 16
%MWxxxxx_A***	0-65535	String	Read Only	03, 16
%DWxxxxx_S	0-65534	Long	Read/Write	03, 06, 16
%DWxxxxx_B	0-65534	LBCD	Read/Write	03, 06, 16
M_%MWxxxxx_n(H) String with HiLo Byte Order (H optional)	xxxxx=0-65535 n is string length range is 1 to 120 words	String	Read/Write	03, 16
M_%MWxxxxx_nL String with LoHi Byte Order	xxxxx=0-65535 n is string length range is 1 to 120 words	String	Read/Write	03, 16

*For slave devices, Read Only locations are Read/Write.

**For more information, refer to "Use 0-Based Bit Addressing" under [Settings](#).

***The length of the string is 2 bytes.

Array Support

Arrays are supported for the holding register addresses. The syntax for declaring an array using decimal addressing is as follows:

%MWxxxxx_cols with assumed row count of 1.
%MWxxxxx_rows_cols.

For Word, Short, and BCD arrays, the base address+(rows*cols) cannot exceed 65535.

For Float, DWord, Long, and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65534.

For all arrays, the total number of registers being requested cannot exceed the holding register block size that was specified for the device.

String Support

The Appicom model supports reading and writing holding register memory as an ASCII string. When using holding registers for string data, each register will contain two bytes of ASCII data. The length of the string can be from 1 to 120 words. For more information on performing block read on string tags, refer to [Block Sizes](#).

Note: String length may be limited by the maximum size of the write request allowed by the device. If the error message "Unable to write to address <address> on device<device> : Device responded with exception code 3" is

received in the server event window, the device did not like the length of the string. If possible, try shortening the string.

TSX Quantum

Output Coils

Address	Range	Data Type	Access	Function Code
0xxxxx	1-65536	Boolean	Read/Write	01, 05, 15

Array Support

Arrays are supported for the output coil addresses. The syntax for declaring an array is as follows:

0xxxxx_cols with assumed row count of 1.
0xxxxx_rows_cols.

The base address+(rows*cols) cannot exceed 65536. The total number of coils being requested cannot exceed the output coil block size that was specified for the device.

Input Coils

Address	Range	Data Type	Access	Function Code
1xxxxx	1-65536	Boolean	Read Only	02

Array Support

Arrays are supported for the input coil addresses. The syntax for declaring an array is as follows:

1xxxxx_cols with assumed row count of 1.
1xxxxx_rows_cols.

The base address+(rows*cols) cannot exceed 65536. The total number of coils being requested cannot exceed the input coil block size that was specified for the device.

Internal Registers

The default data types are shown in **bold**.

Address	Range	Data Type	Access*	Function Code
3xxxxx	1-65536 1-65535 1-65533	Word , Short, BCD Float, DWord, Long, LBCD Double	Read Only	04
3xxxxx.bb	xxxxx=1-65536 bb=0/1-15/16**	Boolean	Read Only	04
3xxxxx:Xbb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read Only	04
D3xxxxx	1-65535	DWord	Read Only	04
F3xxxxx	1-65535	Float	Read Only	04
3xxxxx_S	1-65536	Short	Read Only	04
3xxxxx_B	1-65536	BCD	Read Only	04
3xxxxx_A***	1-65536	String	Read Only	04
D3xxxxx_S	1-65535	Long	Read Only	04
D3xxxxx_B	1-65535	LBCD	Read Only	04
M_3xxxxx_n(H) String with HiLo Byte Order (H optional)	xxxxx=1-65536 n is string length range is 1 to 120 words	String	Read Only	04
M_3xxxxx_nL String with LoHi Byte Order	xxxxx=1-65536 n is string length range is 1 to 120 words	String	Read Only	04

*For slave devices, Read Only locations are Read/Write.

**For more information, refer to "Use 0-Based Bit Addressing" under [Settings](#).

***The length of the string is 2 bytes.

Array Support

Arrays are supported for the internal register addresses. The syntax for declaring an array is as follows:

3xxxxx_cols with assumed row count of 1.
3xxxxx_rows_cols.

For Word, Short, and BCD arrays, the base address+(rows*cols) cannot exceed 65536.
For Float, DWord, Long, and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65535.
For all arrays, the total number of registers being requested cannot exceed the internal register block size that was specified for the device.

Holding Registers

The default data types are shown in **bold**.

Address	Range	Data Type	Access*	Function Code
4xxxxx	1-65536 1-65535 1-65533	Word , Short, BCD Float, DWord, Long, LBCD Double	Read/Write	03, 06, 16
4xxxxx.bb	xxxxx=1-65536 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
4xxxxx:Xbb	xxxxx=0-65535 bb=0/1-15/16**	Boolean	Read/Write	03, 06, 16, 22
D4xxxxx	1-65535	DWord	Read/Write	03, 06, 16
F4xxxxx	1-65535	Float	Read/Write	03, 06, 16
4xxxxx_S	1-65536	Short	Read/Write	03, 06, 16
4xxxxx_B	1-65536	BCD	Read/Write	03, 06, 16
4xxxxx_A***	1-65536	String	Read Only	03, 16
D4xxxxx_S	1-65535	Long	Read/Write	03, 06, 16
D4xxxxx_B	1-65535	LBCD	Read/Write	03, 06, 16
M_4xxxxx_n(H) String with HiLo Byte Order (H optional)	xxxxx=1-65536 n is string length range is 1 to 120 words	String	Read/Write	03, 16
M_4xxxxx_nL String with LoHi Byte Order	xxxxx=1-65536 n is string length range is 1 to 120 words	String	Read/Write	03, 16

*For slave devices, Read Only locations are Read/Write.

**For more information, refer to "Use 0-Based Bit Addressing" under [Settings](#).

***The length of the string is 2 bytes.

Array Support

Arrays are supported for the holding register addresses. The syntax for declaring an array using decimal addressing is as follows.

4xxxxx_cols with assumed row count of 1.
4xxxxx_rows_cols.

For Word, Short, and BCD arrays, the base address+(rows*cols) cannot exceed 65536.
For Float, DWord, Long, and Long BCD arrays, the base address+(rows*cols*2) cannot exceed 65535.
For all arrays, the total number of registers being requested cannot exceed the holding register block size that was specified for the device.

String Support

The Applicom model supports reading and writing holding register memory as an ASCII string. When using holding registers for string data, each register will contain two bytes of ASCII data. The length of the string can be from 1 to 120 words. For information on performing a block read on string tags, refer to [Block Sizes](#).

Note: String length may be limited by the maximum size of the write request allowed by the device. If the error message "Unable to write to address <address> on device<device>: Device responded with exception code 3" is received in the server event window, the device did not like the length of the string. If possible, try shortening the string.

Error Descriptions

The following error/warning messages may be generated. Click on the link for a description of the message.

Address Validation

[Address '<address>' is out of range for the specified device or register](#)
[Array size is out of range for address '<address>'](#)
[Array support is not available for the specified address: '<address>'](#)
[Data Type '<type>' is not valid for device address '<address>'](#)
[Device address '<address>' contains a syntax error](#)
[Device address '<address>' is not supported by model '<model name>'](#)
[Device address '<address>' is Read Only](#)
[Missing address](#)

Device Status Messages

[Device '<device name>' is not responding](#)
[Failed to resolve host '<host name>' on device '<device name>'](#)
[Unable to bind to adapter: '<network adapter name>'. Connect failed](#)
[Unable to create a socket connection for device '<device name>'](#)
[Unable to write to '<address>' on device '<device name>'](#)
[Unable to write to address '<address>' on device '<device>': Device responded with exception code '<code>'](#)

Device Specific Messages

[Bad address in block \[x to y\] on device '<device name>'](#)
[Bad array spanning \['<address>' to '<address>'\] on device '<device name>'](#)
[Bad received length \[x to y\] on device '<device name>'](#)
[Cannot change device ID '<device ID>' from '<current mode>' to '<new mode>' with a client connected](#)
[Failure to initiate 'winsock.dll'](#)
[Failure to start unsolicited communications](#)
[Unsolicited mailbox access for undefined device \(IP: '<device IP>'. '<device index>'\)...Closing socket](#)
[Unsolicited mailbox memory allocation error \(IP: '<device IP>'\)](#)
[Unsolicited mailbox unsupported request received \(IP: '<device IP>'\)](#)

Automatic Tag Database Generation Messages

[Description truncated for import file record number '<record>'](#)
[Error parsing import file record number '<record>', field '<field>'](#)
[File exception encountered during tag import](#)
[Imported tag name '<tag name>' is invalid. Name changed to '<tag name>'](#)
[Tag '<tag name>' could not be imported because data type '<data type>' is not supported](#)
[Tag import failed due to low memory resources](#)

See Also:

[Modbus Exception Codes](#)

Address Validation

The following error/warning messages may be generated. Click on the link for a description of the message.

Address Validation

[Address '<address>' is out of range for the specified device or register](#)
[Array size is out of range for address '<address>'](#)
[Array support is not available for the specified address: '<address>'](#)
[Data Type '<type>' is not valid for device address '<address>'](#)
[Device address '<address>' contains a syntax error](#)
[Device address '<address>' is not supported by model '<model name>'](#)
[Device address '<address>' is Read Only](#)
[Missing address](#)

Address '<address>' is out of range for the specified device or register

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically references a location that is beyond the range of supported locations for the device.

Solution:

Verify that the address is correct; if it is not, re-enter it in the client application.

Array size is out of range for address '<address>'

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically is requesting an array size that is too large for the address type or block size of the driver.

Solution:

Re-enter the address in the client application to specify either a smaller value for the array or a different starting point.

Array support is not available for the specified address: '<address>'

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically contains an array reference for an address type that doesn't support arrays.

Solution:

Re-enter the address in the client application to remove the array reference or correct the address type.

Data Type '<type>' is not valid for device address '<address>'

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically has been assigned an invalid data type.

Solution:

Modify the requested data type in the client application.

Device address '<address>' contains a syntax error

Error Type:

Warning

Possible Cause:

An invalid tag address has been specified in a dynamic request.

Solution:

Re-enter the address in the client application.

Device address '<address>' is not supported by model '<model name>'

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically references a location that is valid for the communications protocol but not supported by the target device.

Solution:

Verify that the address is correct; if it is not, re-enter it in the client application. Verify also that the selected model name for the device is correct.

Device address '<address>' is Read Only

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically has a requested access mode that is not compatible with what the device supports for that address.

Solution:

Change the access mode in the client application.

Missing address

Error Type:

Warning

Possible Cause:

A tag address that has been specified statically has no length.

Solution:

Re-enter the address in the client application.

Device Status Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Device Status Messages

[Device '<device name>' is not responding](#)

[Failed to resolve host '<host name>' on device '<device name>'](#)

[Unable to bind to adapter: '<network adapter name>'. Connect failed](#)

[Unable to create a socket connection for device '<device name>'](#)

[Unable to write to '<address>' on device '<device name>'](#)

[Unable to write to address '<address>' on device '<device>': Device responded with exception code '<code>'](#)

Device '<device name>' is not responding

Error Type:

Serious

Possible Cause:

1. The connection between the device and the Host PC is broken.
2. The communication parameters for the connection are incorrect.
3. The named device may have been assigned an incorrect Network ID.

Solution:

1. Verify the cabling between the PC and the device.
2. Verify that the specified communication parameters match those of the device.
3. Verify that the Network ID given to the named device matches that of the actual device.

Failed to resolve host '<host name>' on device '<device name>'

Error Type:

Fatal

Possible Cause:

The device is configured to use a DNS host name rather than an IP address. The host name cannot be resolved by the server to an IP address.

Solution:

Verify that the device is online and registered with the domain.

Unable to bind to adapter: '<network adapter name>'. Connect failed

Error Type:

Warning

Possible Cause:

Since the specified network adapter cannot be located in the system device list, it cannot be bound to for communications. This usually occurs when a project is moved from one PC to another (and when the project specifies a network adapter rather than using the default). The server falls back to the default adapter.

Solution:

Change the Network Adapter property to Default (or select a new adapter) and then save the project and retry.

Unable to create a socket connection for device '<device name>'

Error Type:

Warning

Possible Cause:

The server was unable to establish a TCP/IP socket connection to the specified device. It will continue to attempt connection.

Solution:

1. Verify that the device is online.
2. Verify that the device IP is within the subnet of the IP to which the server is bound. Alternatively, verify that a valid gateway is available that allows a connection the other network.

Unable to write to '<address>' on device '<device name>'

Error Type:

Serious

Possible Cause:

1. The named device may not be connected to the network.
2. The named device may have been assigned an incorrect Network ID.
3. The named device is not responding to write requests.
4. The address does not exist in the PLC.

Solution:

1. Check the PLC network connections.
2. Verify the Network ID given to the named device matches that of the actual device.

Unable to write to address '<address>' on device '<device>': Device responded with exception code '<code>'

Error Type:

Warning

Possible Cause:

See [Modbus Exception Codes](#) for a description of the exception code.

Solution:

See [Modbus Exception Codes](#).

Device Specific Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Device Specific Messages

[Bad address in block \[x to y\] on device '<device name>'](#)

[Bad array spanning \['<address>' to '<address>'\] on device '<device name>'](#)

[Bad received length \[x to y\] on device '<device name>'](#)

[Cannot change device ID '<device ID>' from '<current mode>' to '<new mode>' with a client connected](#)

[Failure to initiate 'winsock.dll'](#)

[Failure to start unsolicited communications](#)

[Unsolicited mailbox access for undefined device \(IP: '<device IP>'. '<device index>'\)...Closing socket](#)

[Unsolicited mailbox memory allocation error \(IP: '<device IP>'\)](#)

[Unsolicited mailbox unsupported request received \(IP: '<device IP>'\)](#)

Bad address in block [x to y] on device '<device name>'

Error Type:

Fatal addresses falling in this block.

Possible Cause:

This error is reported when the driver attempts to read a location in a PLC that does not exist. For example, in a PLC that only has holding registers 40001 to 41400, requesting address 41405 would generate this error. Once this error is generated, the driver will not request the specified block of data from the PLC again. Any other addresses being requested that are in this same block will also go invalid.

Solution:

The client application should be modified to ask for addresses within the range of the device.

See Also:

[Error Handling](#)

Bad array spanning ['<address>' to '<address>'] on device '<device name>'

Error Type:

Fatal

Possible Cause:

An array of addresses was defined that spans past the end of the address space.

Solution:

Verify the size of the device's memory space and then redefine the array length accordingly.

Bad received length [x to y] on device '<device name>'

Error Type:

Fatal addresses falling in this block.

Possible Cause:

The driver attempted to read a block of memory in the PLC. The PLC responded with no error, but did not provide the driver with the requested block size of data.

Solution:

Ensure that the range of memory exists for the PLC.

Cannot change device ID '<device ID>' from '<current mode>' to '<new mode>' with a client connected

Error Type:

Warning

Possible Cause:

When a client is connected, the Device ID can only be changed if it does not result in change of mode (master to slave or slave to master) of the device. The mode is changed by changing the loopback* or local IP address to a different IP address and vice versa. The loopback address and the local IP address (of the PC running the driver) indicates slave (unsolicited) mode, and any other IP address indicates master mode of the device.

*Any address in the format 127.xxx.xxx.xxx, where xxx is in the range 0-255, is the loopback address.

Solution:

To change the Device ID that results in change of mode (master to slave OR slave to master), disconnect all the clients.

Note:

For this driver, the terms Slave and Unsolicited are used interchangeably.

Failure to initiate 'winsock.dll'

Error Type:

Fatal

Possible Cause:

Could not negotiate with the operating systems winsock 1.1 functionality.

Solution:

Verify that the winsock.dll is properly installed on the system.

Failure to start unsolicited communications

Error Type:

Fatal

Possible Cause:

The driver was not able to create a listen socket for unsolicited communications.

Solution:

Call a Technical Support representative.

Note:

For this driver, the terms Slave and Unsolicited are used interchangeably.

Unsolicited mailbox access for undefined device (IP: '<device IP>'. '<device index>')...Closing socket

Error Type:

Warning

Possible Cause:

A device with the specified IP address attempted to send a mailbox message to the server. The message did not pass validation, due to one of the following reasons:

1. There is no device with that IP configured in the Mailbox Project.
2. Although a device is configured, there are no clients requesting data from it.

Solution:

In order for the server to accept mailbox messages, the specified Device IP must be configured in the project. At least one data item from the device must be requested by a client.

Unsolicited mailbox memory allocation error (IP: '<device IP>')

Error Type:

Fatal

Possible Cause:

An attempt made to allocate memory for the specified IP address failed.

Solution:

The server was unable to increase the working memory set for additional Mapped Memory addresses. This will occur if there is no more RAM or Virtual RAM available for the server to use. To check for available memory, use the Task Manager. Update the machine to accommodate the demands of the project, if necessary.

Unsolicited mailbox unsupported request received (IP: '<device IP>')

Error Type:

Warning

Possible Cause:

An unsupported request was received from the specified Device IP. The format of the device's request was invalid and not within Modbus specification.

Solution:

Verify that the devices configured to send Mailbox data are sending the correct requests.

Automatic Tag Database Generation Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Automatic Tag Database Generation Messages

[Description truncated for import file record number '<record>'](#)

[Error parsing import file record number '<record>', field '<field>'](#)

[File exception encountered during tag import](#)

[Imported tag name '<tag name>' is invalid. Name changed to '<tag name>'](#)

[Tag '<tag name>' could not be imported because data type '<data type>' is not supported](#)

[Tag import failed due to low memory resources](#)

Description truncated for import file record number '<record>'

Error Type:

Warning

Possible Cause:

The tag description given in specified record is too long.

Solution:

The driver will truncate the description as needed. To prevent this error in the future, edit the variable import file to change the description (if possible).

Error parsing import file record number '<record>', field '<field>'

Error Type:

Serious

Possible Cause:

The specified field in the variable import file could not be parsed because it is longer than expected or invalid.

Solution:

Edit the variable import file to change the offending field if possible.

File exception encountered during tag import

Error Type:

Serious

Possible Cause:

The variable import file could not be read.

Solution:

Regenerate the variable import file.

Imported tag name '<tag name>' is invalid. Name changed to '<tag name>'

Error Type:

Warning

Possible Cause:

The tag name encountered in the variable import file contained invalid characters.

Solution:

The driver will construct a valid name based on the one from the variable import file. To prevent this error in the future and to maintain name consistency, change the name of the exported variable if possible.

Tag '<tag name>' could not be imported because data type '<data type>' is not supported

Error Type:

Warning

Possible Cause:

The data type specified in the variable import file is not one of the types supported by this driver.

Solution:

If possible, change the data type specified in variable import file to one of the supported types. If the variable is for a structure, manually edit the file in order to define each tag required for the structure. Alternatively, manually configure the required tags in the OPC server.

See Also:

[Exporting Variables from Concept](#)

Tag import failed due to low memory resources

Error Type:

Serious

Possible Cause:

The driver could not allocate memory required to process variable import file.

Solution:

Shut down all unnecessary applications and retry.

Modbus Exception Codes

The following data is from Modbus Application Protocol Specifications documentation.

Code Dec/Hex	Name	Meaning
01/0x01	ILLEGAL FUNCTION	The function code received in the query is not an allowable action for the server (or slave). This may be because the function code is only applicable to newer devices, and was not implemented in the unit selected. It could also indicate that the server (or slave) is in the wrong state to process a request of this type; for example, because it is unconfigured and is being asked to return register values.
02/0x02	ILLEGAL DATA ADDRESS	The data address received in the query is not an allowable address for the server (or slave). More specifically, the combination of reference number and transfer length is invalid. For a controller with 100 registers, a request with offset 96 and length 4 would succeed, a request with offset 96 and length 5 will generate exception 02.
03/0x03	ILLEGAL DATA VALUE	A value contained in the query data field is not an allowable value for server (or slave). This indicates a fault in the structure of the remainder of a complex request, such as that the implied length is incorrect. It specifically does NOT mean that a data item submitted for storage in a register has a value outside the expectation of the application program, since the MODBUS protocol is unaware of the significance of any particular value of any particular register.
04/0x04	SLAVE DEVICE FAILURE	An unrecoverable error occurred while the server (or slave) was attempting to perform the requested action.
05/0x05	ACKNOWLEDGE	The slave has accepted the request and is processing it, but a long duration of time will be required to do so. This response is returned to prevent a timeout error from occurring in the master. The master can next issue a Poll Program Complete message to determine if processing is completed.
06/0x06	SLAVE DEVICE BUSY	The slave is engaged in processing a long duration program command. The master should retransmit the message later when the slave is free.
07/0x07	NEGATIVE ACKNOWLEDGE	The slave cannot perform the program function received in the query. This code is returned for an unsuccessful programming request using function code 13 or 14 decimal. The master should request diagnostic or error information from the slave.

08/0x08	MEMORY PARITY ERROR	The slave attempted to read extended memory but detected a parity error in the memory. The master can retry the request, but service may be required on the slave device.
10/0x0A	GATEWAY PATH UNAVAILABLE	Specialized use in conjunction with gateways indicates that the gateway was unable to allocate an internal communication path from the input port to the output port for processing the request. This usually means that the gateway is misconfigured or overloaded.
11/0x0B	GATEWAY TARGET DEVICE FAILED TO RESPOND	Specialized use in conjunction with gateways indicates that no response was obtained from the target device. This usually means that the device is not present on the network.

Note: For this driver, the terms Slave and Unsolicited are used interchangeably.

Index

A

Address '<address>' is out of range for the specified device or register.....	33
Address Descriptions.....	21
Address Validation.....	32
Applicom Addressing.....	26
Array size is out of range for address '<address>'.....	33
Array support is not available for the specified address: '<address>'.....	33
Automatic Tag Database Generation.....	15
Automatic Tag Database Generation Messages.....	38

B

Bad address in block [x to y] on device '<device name>'.....	36
Bad array spanning ['<address>' to '<address>'] on device '<device name>'.....	36
Bad received length [x to y] on device '<device name>'.....	36
Block Sizes.....	11

C

Cable Diagrams.....	13
Cannot change device ID '<device ID>' from '<current mode>' to '<new mode>' with a client connected.....	36
Channel Setup.....	5
Communications Timeout.....	13

D

Data Type '<type>' is not valid for device address '<address>'.....	33
Data Types Description.....	20
Description truncated for import file record number '<record>'.....	38
Device '<device name>' is not responding.....	34
Device address '<address>' contains a syntax error.....	33
Device address '<address>' is not supported by model '<model name>'.....	33
Device address '<address>' is Read Only.....	34
Device ID (PLC Network Address).....	7
Device Setup.....	7
Device Specific Messages.....	35
Device Status Messages.....	34
Driver System Tag Addressing.....	25

E

Error Descriptions.....	32
Error Handling.....	12
Error parsing import file record number '<record>', field '<field>'.....	38
Ethernet.....	8
Ethernet to Modbus Plus Bridge.....	8
Exporting Variables from Concept.....	15
Exporting Variables from ProWORX.....	17

F

Failed to resolve host '<host name>' on device '<device name>'.....	34
Failure to initiate 'winsock.dll'.....	37
Failure to start unsolicited communications.....	37
File exception encountered during tag import.....	38
Fluenta.....	8
Fluenta Addressing.....	26

G

Generic Modbus.....	26
---------------------	----

H

Help Contents.....	4
Holding Registers.....	23

I

Imported tag name '<tag name>' is invalid. Name changed to '<tag name>'.....	38
Input Coils.....	22
Instromet.....	8
Instromet Addressing.....	26
Internal Registers.....	22

M

Mailbox.....	7
--------------	---

Mailbox Addressing	25
Missing Address	34
Modbus Addressing	21
Modbus Exception Codes	39
Modbus Master	7
Modbus Master & Modbus Unsolicited Considerations	14
Modbus Unsolicited	7

O

Optimizing Modbus TCP/IP Ethernet Communications	19
Output Coils	21
Overview	4

P

Port Tag	25
----------------	----

R

Roxar	8
Roxar Addressing	26

S

Settings	9
Socket Usage	5

T

Tag '<tag name>' could not be imported because data type '<data type>' is not supported	39
Tag import failed due to low memory resources	39
TSX Premium	28
TSX Quantum	30

U

Unable to bind to adapter: '<network adapter name>'. Connect failed	35
Unable to create a socket connection for Device '<device name>'	35
Unable to write to '<address>' on device '<device name>'	35

Unable to write to address '<address>' on device '<device>': Device responded with excep-	35
tion code '<code>'.....	
Unsolicited.....	12
Unsolicited mailbox access for undefined device (IP: '<device IP>'. '<device index>').-	37
..Closing socket.....	
Unsolicited mailbox memory allocation error (IP: '<device IP>').....	37
Unsolicited mailbox unsupported request received (IP: '<device IP>').....	37

V

Variable Import Settings.....	12
-------------------------------	----